

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215086
Address: 2610 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, April 18, 2022

Corrective Action Required:

1	Misc	-Anchor bolts to be in the middle 1/3 of sill plate -stud pack per plans at garage for beam above -address cut joist in garage for dwv -roof supports above single car garage per plans -fire block under garage stairs -uncover covered patio for inspection -secure gas line at fireplace -missing nails at hanger near bottom of stairs -anchor steel columns in basement -anchor bolts within 12" of sill plate break in garage /basement -all anchor bolts to be tight basement and garage
---	------	---

Comments: