

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211576
Address: 429 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Partial	Monday, April 18, 2022

Informational:

1	Misc	Forms were placed and aggregate was present and compacted. RP 3-24-22
---	------	---

Corrective Action Required:

2	Misc	Cross slope measuring from 2.8% to 8.4%. ADA maximum slope allowed is 2.0%. Entire approach needs to be removed and replaced. RP 4-1-22
---	------	---

Informational:

3	Misc	Forms were placed and aggregate was present and compacted. Talked with Wes and informed him to keep it below 2% cross slope. RP 4-18-22
---	------	---

Comments: