

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212479
Address: 3112 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, April 18, 2022

Corrective Action Required:

1	Misc	4/12/22 - RESCHEDULE INSPECTION WHEN ALL CORRECTIONS COMPLETE
---	------	---

Spoke with ethan with summit homes.
requesteed a TCO extension, TCO extened until
4/14/22

-lower water meter lid to grade, maintain required 14" - 18" clearance from
top of meter to top of lid

Comments: