

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204934  
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Michael Harkins	Failed	Monday, April 18, 2022

Corrective Action Required:

1	Misc	04/06/22 Wednesday (Star Development - Aaron (816) 807-2502) Silt fence has failed throughout the project. Silt fence needs to be re-staked and repaired. 04/18/22 Monday (Star Development- Aaron) I called contractor and informed him that the erosion control had failed. He expected the erosion fencing company to be out in the next few days. I will check site again to follow up progress on re-establishing erosion control measures.
---	------	---

**Comments:**