

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20220226  
**Address:** 4871 SW RAINTREE PKWY, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Patrick Schonfeldt	Failed - Stop Work	Monday, April 18, 2022

Corrective Action Required  
1 Misc

-FOOTING POURED WITHOUT INSPECTION-

ENGINEER REPORT REQUIRED TO BE UPLOADED WITHIN 48  
HOURS OF INSPECTION

STOP WORK ISSUED

**Comments:**