

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220820  
Address: 813 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Tuesday, April 19, 2022

Corrective Action Required:

1	Misc	-Support&secure MC within 12" of boxes
---	------	--

\*\*Existing NM circuits within suspended ceiling space remains in place. Wiring from existing j-boxes to new electrical outlets are in MC cables

**Comments:**