

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204940
Address: 322 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Tuesday, April 19, 2022

Corrective Action Required:

1	Misc	tighten GC in main panel
2	Miscellaneous Correction	Identify ufer ground with green tape on both ends

Comments: