

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213528
Address: 2361 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|-------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Tuesday, April 19, 2022 |

Corrective Action Required:

1 Misc

- Provide 3 1/2" steel columns both sides of gaming room per plan
- Seal penetration in RA at bed 4 in furr down

Okay to insulate, do not cover any items still in need of inspection.

Corrective Action Required:

2 Misc

Comments: