

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213807
Address: 2101 SW RUTHERFORD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, April 19, 2022

Corrective Action Required:

1	Misc	-provide floor outlet stair wall -secure all vertical DWV 2" or less at mid point -nail all truss hangers master bed -secure wiring at home run front bed -address damaged plates at V1 valley rafter -have engineer with truss manufacturer address broken C2 truss above foyer -all truss lateral bracing per plans -nail off all truss H2.5 clips -solid block between joists every 48" oc kitchen island per plans
---	------	--

Comments: