

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214077
Address: 3104 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Not Ready	Wednesday, April 20, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Provide front door- Fire block chase at top plate at DWV garage- Nail all exterior intersecting corners to code- Strap both sides of entry top plate not tied in- Address broken trusses A2 in kitchen-upload letter to portal for inspection- fire block top plate at soffit basement north west corner- Fire block soffit to joist space at basement door and bedroom 4 at beam- Security blocking basement door-at hinges |
|---|--------------------------|---|

Comments: