

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215873
Address: 1624 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, April 20, 2022

Corrective Action Required:

1	Misc	-fireblock furr out wall right of garage entry -strike plate at NM left of patio slider -complete cspf at rear breakfast and living room to plans/code -fire block dining room to garage furr down -complete cs-pf at dining -protect NM with in 6ft of attic access 2nd floor
---	------	---

Comments: