

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213712
Address: 1909 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, April 20, 2022

Corrective Action Required:

1	Misc	**BELOW CORRECTIONS CARRIED OVER FROM ALL ROUGH** -Provide (2) 1/2" through bolts at all post to beam connections at deck -Provide lag bolts or approved fasteners at deck ledger -Install missing hanger nails at deck -provide flashing at deck ledger
---	------	---

Comments: