

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213070
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Wednesday, April 20, 2022

Corrective Action Required:

1	Misc	-Install #4 copper jumper from the lower bus bar where the GECs are connected to, to the upper grounded bus bar. NEC 250.24(A)&(A)(4) -SE cable is outside wall space
---	------	--

Comments: