

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215503
Address: 142 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, April 20, 2022

Corrective Action Required:

1	Miscellaneous Correction	Install deck fire place & secure gas line Provide CS-PF bracing per plan west of great room fire place (still needs straps per 2018 IRC R602.10.6.4) Install furnace (gas line) Seal fire blocking at hose bib bed 4 closet (vertical to horizontal at top plate at furr out) Nail exterior wall sheathing per code Provide flashing above exterior horizontal window trim throughout
---	--------------------------	--

Comments: