

DEVELOPMENT SERVICES**Residential Plan Review**

April 20, 2022

CLAYTON PROPERTIES GROUP, INC
120 SE 30TH ST
LEES SUMMIT, MO 64082
(816) 246-6700

Permit No: PRRES20221554
Plan Name:
Project Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082
Parcel Number: 70500041500000000
Location: COBEY CREEK - 1ST PLAT---LOT 148
Type of Work: NEW SINGLE FAMILY
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY
Description: NEW HOUSE - UNFINISHED BASEMENT - UNCOVERED PATIO

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Residential Plan Review**Reviewed By: Kim Brennan****Approved**

1. Designate locations of smoke detectors and carbon monoxide detectors. (IRC Section R314 and R315)

Not shown on the main level

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Residential, garage		420	
Residential, Living Area (Not Finished Basement)		1817	
Residential, Un-Finished basements		587	
Roofing Material		Number of Bathrooms	2.5
Number of Bedrooms	3	Number of Stories	2
Number of Living Units	1	Total Living Area	1817
Sewer Connection Fee	14		

