



## **FIRE DEPARTMENT**

**Prevention Division  
(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20220365	Date:	April 20, 2022
Project Title:	LEES SUMMIT MEDICAL CENTER ICU	Applicant:	
ADDITION			
Location:		American Fire Sprinkler Corporation	
2100 SE BLUE PKWY, LEES SUMMIT, MO 64063		6750 W 47th Terrace	
Type of Work:		Kansas, MO 66203	
Occupancy Group:	I-2	Primary: (913) 722-6900	Ext: 125
Description:	ADDITION TO EXISTING HOSPITAL		
ICU			
Construction Type:	Type IB		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received 4/13/2022.

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a hydrstatic test and above ceiling inspection.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**