

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213383
Address: 3204 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, April 21, 2022

Corrective Action Required:

1	Misc	-lib's installed to code -anchor bolts to be tight -address overboard stud at service panel -fire block top or furred out walls in garage to ceiling space -seal top plate penetrations in bath 4 -midway strap all dwv 2" in diameter or less -fire block dead space near garage entry -fire block hvac chase into ceiling space -fire block dining into garage furr down -complete cspf at dining -protect NM within 6' of attic access -seal bottom plat penetration laundry to bath 1 -add solid blocking one joist bay past kitchen island above in basement -seal penetrations though out -add missing hanger at rear patio
---	------	---

Comments: