

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213827
Address: 4709 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, April 21, 2022

Corrective Action Required:

1	Misc	-Strap garage PFH wall header **get longer straps. Strap to extend min 2 ft beyond header
		-Provide fall protection for bedroom windows
		-Strap across cut top plates at front bedroom gable wall

Comments: