

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212062  
Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Ronald Paynter	Failed	Friday, April 22, 2022

Informational:  
1            Misc            Forms were placed and aggregate was present and compacted. Had them adjust the forms around the curb inlet because they were out of tolerance. RP 4-13-22

Corrective Action Required:  
2            Misc            Sidewalk covered with silt. Need to clean off before final inspection for compliance. RP 4-22-22

**Comments:**