

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20211374
Address: 1917 NE CATALINA AVE, LEES SUMMIT, MO 64064
Inspected On: Friday, April 22, 2022
Inspected By: Khanh Nguyen
Expiration Date: 5/23/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Friday, April 22, 2022

Corrective Action Required:

1	Misc	-Final grade, sod, downspout and sump pump extension -Provide sewer tracer wire port at grade -Provide receptacle spacing per code for cabinet with countertop left side of fireplace
---	------	---