

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212347  
Address: 146 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Passed	Friday, April 22, 2022

Informational:  
1 Misc Forms were placed and aggregate was present and compacted. Combined, the 2 driveways were over 36 feet wide. Dan removed the wings and now we are under 34 feet wide. RP 4-13-22

Informational:  
2 Misc Finished driveways meet LS and ADA specs. RP 4-22-22

**Comments:**