

ANALYTICAL REPORT

February 17, 2022

Work Order: 1FB1548

Page 1 of 3

Report To

Tom Taylor
City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

Work Order Information

Date Received: 02/16/2022 11:50AM
Collector: Client
Phone: (816) 969-7428
PO Number: Routine Analysis

Project : C.P. Excavating LLC

Project Number: Princeton Senior Living

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1FB1548-01	#4 Water Domestic			Matrix:Drink Wtr		Collected: 02/16/22 10:45	
Total Coliforms	<1.0 MPN/100ml	1.0	1FB0818	9223B-QT	CLJ	02/16/22 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1FB0818	9223B-QT	CLJ	02/16/22 16:30	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

ANALYTICAL REPORT

February 16, 2022

Work Order: 1FB1394

Page 1 of 3

Report To

Tom Taylor
City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

Work Order Information

Date Received: 02/15/2022 12:50PM
Collector: Client
Phone: (816) 969-7428
PO Number: Routine Analysis

Project : C.P. Excavating LLC

Project Number: Princeton Senior Living

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1FB1394-01	Senior Bldg			Matrix:Drink Wtr		Collected: 02/15/22 11:12	
Total Coliforms	<1.0 MPN/100ml	1.0	1FB0758	9223B-QT	CLJ	02/15/22 16:30	
E. Coli	<1.0 MPN/100ml	1.0	1FB0758	9223B-QT	CLJ	02/15/22 16:30	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.