CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214597

Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Hood/Duct Inspection Michael Harkins Passed Friday, April 22, 2022

Informational:

1 Miscellaneous WELDS APPROVED FOR 1ST LAYER WRAP
Correction 1ST LAYER WRAP APPROVED FOR 2ND LAYER

2ND LAYER & BANDING APPORVED

Comments: