

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220820
Address: 813 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|------------------------|
| Occupancy Inspection - Codes Commercial | Khanh Nguyen | Failed | Friday, April 22, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Install fire extinguishers per Fire -Provide ADA compliant door knob for restroom door. Knob shall be operational without twisting of wrists -Provide protection under restroom sink -Provide open front toilet seat; The flush lever must be on the approach side of the bowl -Install cover plate for receptacle in restroom. Receptacle in restroom must be gfci-protected -All receptacles located within six ft of the sinks must be gfci-protected |
|---|------|--|

Comments: