

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211547  
Address: 3073 NW THOREAU LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Passed	Friday, April 22, 2022

Informational:

1 Misc

Driveway is 34.5 feet wide. Forms were placed and aggregate was present and compacted. RP 4-8-22

Informational:

2 Misc

Finished driveway meets LS specs. RP 4-22-22

**Comments:**