

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212885
Address: 2114 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Friday, April 22, 2022

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	4/22/22 EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -PROVIDE EROSION CONTROL AT PERIMETER AND MAINTAIN UNTIL SOD IS IN PLACE. CLEAN DEBRIS FROM STREETS
---	---	--

Comments: