

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211211

Address: 628 NW WILLOW DR, LEES SUMMIT, MO 64081626 NW WILLOW DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Failed	Friday, April 22, 2022

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	1ST LAYER TYPE X PARTY WALL, ATTIC, RAFTERS UNITS 626 & 628 2ND LAYER TYPE X UNITS 626 & 628
---	----------------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	FIRE CAULK ALL PENETRATIONS IN RATED WALL  Seal penetrations at ridge of Rated assembly ( provide ladder for access )
---	--------------------------	---

**Comments:**