

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211211

Address: 628 NW WILLOW DR, LEES SUMMIT, MO 64081 626 NW WILLOW DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, April 22, 2022

Corrective Action Required:

1	Miscellaneous Correction	626 & 628 Seal penetrations at ridge of Rated assembly (provide ladder for access) Provide Hi / lo vent mechanical rooms to exterior per combustion air letter dated 5/11/21 from AFC heating & cooling Provide sod & splash blocks Sump shall discharge 36" from foundation 626 Provide GFCI protection garage receptacles Provide anti tip device range Provide GFCI protection washing machine 628 Provide GFCI protection washing machine Provide GFCI protection master vanity (open ground) Provide anti tip device range Provide GFCI protection garage receptacles
---	--------------------------	---

Comments:

