

## **Third Party Inspection Report**

Inspector	Date	Time									
David P. Ainsworth, P.E.	4-22-22	2:45 PM									
Company	Permit #	Permit Holder									
David P. Ainsworth, P.E.	2022-0755	JFE									
Inspection Type	2022-6755 NFE Address RETREAT@HOOK FARMS LOTS!										
FOOTING E-Mail Address	2822 SWHEARTHSTONE PL LSMG										
E-Mail Address dainsworth@chelepis.com											
Instructions: This form must be completed when performing a third party inspection for any building											
permit in Lee's Summit. Submit form within 48 hours after inspection to the Development Services											
Department. If a subsequent inspection is performed by the City, this form must be submitted prior to that inspection being scheduled.											
Check all boxes that apply to the site conditions and the inspection being performed.											
Site Conditions:											
Plans stamped by the City on site with the plot plan included. (Copied plans are not acceptable)											
Erosion controls in place and r	Erosion controls in place and maintained										
*Note: If these requirements are not met no inspection shall be performed or accepted by the City.											
Foundations and Footings:											
Foundation type and MBOE is equal to or above the plot plan											
Concrete encased electrode (	Concrete encased electrode (ufer) ground installed (Location must be noted in comments)										
Foundation/Footing meets all engineered design.	Foundation/Footing meets all City Code requirements and matches City approved plans or engineered design.										
<b>Foundation Walls:</b>											
Elevation is sufficient to achie	ve 2% slope away from structure										
No openings below the MBOE											
Concrete encased electrode (	Concrete encased electrode (ufer) ground exposed										
Foundation wall meets all City engineered design.	Foundation wall meets all City Code requirements and matches City approved plans or engineered design.										



-						•				
Ь	r	a	P	٧	P	B	r	ø	$\sigma$	
u		a	ı	e	u	ı	u	8	s	

Framing meets all City Code requirements and matches City approved plans or engineered design.

\*Note: Framing can only be covered after mechanical, electrical, and plumbing inspections have been

## **Corrective Actions and Comments:**

UFER GROUND ROD IS LOCATED IN THE RIGHT SIDEWALL ABOUT 5' BACK FROM THE RIGHT FRONT CORNER.

I certify that I have inspected, tested, and checked the work performed, and I find the work to be compliant with all applicable City ordinances and approved building plans and site plans and that the all information in this form is both accurate and true.

**Engineer/Architect Seal** 

220 SE Green Street | Lee's Summit, MO 64063 | P: 816.969.1200 | F: 816.969.1221 | cityofLS.net