

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212912  
Address: 1725 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, April 25, 2022

Corrective Action Required:

1	Misc	-cspf per plans at master bed(fix to engineer letter specifications "nail sill plate exterior") -add and use proper hangers above master bath tub -strap all dwv 2" or less at midway point -nail floor joists to top plate -nail off hangers above furnace area ( 2 hangers missing nails) -fire block into basement hallway furr down from basement bath
---	------	---

**Comments:**