

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212912
Address: 1725 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Mitchell Schwarz	Failed	Monday, April 25, 2022

Corrective Action Required:

1	Misc	MISSING (1) 18"X36" PIER "J" , EAST SIDE PER PLANS
---	------	--

Corrective Action Required:

2	Misc	above pier to be re poured to depth do not pour until pier hole is inspected. Mitchell Schwarz 04/25/2022 8:58 AM
---	------	--

Comments: