

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20216366

Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT,
MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR,
Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Fire Hydrant	Adam Nacke	Passed	Monday, April 25, 2022

Informational:

1 Misc 4-20-22 AN Holthouse began to expose the water line to install the new fire hydrant on the south end

Informational:

2 Misc 4-21-22 AN. Josh asked if he could use a old existing fire hydrant and I informed him that it had to be a new hydrant

Informational:

3 Misc 4-25-22 the new fire hydrant on the south side fully installed and operational.

Comments: