



## MEMO

**Date:** April 21, 2022

**To:** City of Lee's Summit

**From:** Dan Webster, AIA dan@websterarchitects.com

**Copy:**

**Attachments:**

**Subject:** 3206 SW Pergola Park Dr., Lee's Summit, MO 64082

Permit # PRRES20212684

Bedroom #4. Install ceiling joists at the 10' ceiling height.

Window in gable – Since the wall is not loadbearing, no header is required for the window.

The storm shelter under the front porch is approved as constructed.

