

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215490
Address: 2812 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, April 25, 2022

Corrective Action Required:

1	Misc	-install garage doors -fire block furr out in kitchen into pantry -fire block pantry top plate cut for dwv and pex -secure fireplace in place -seal return air panning above beam in basement seal gaps
---	------	---

Comments: