

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215424
Address: 2038 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, April 25, 2022

Corrective Action Required:

1	Misc	-complete fire place install (protect gas and secure) -fire block gas line at fire place -address rafters over notched through out vaulted ceiling area -fire block top of furr out wall in hall bath -address bath fan vent in hall bath -address lvl rafter not landing on top plate near master bath entry -address roof supports landing on non bearing walls -address non contentious studs at gable wall in living room -fireblock N kitchen wall to ceiling space -seal all bottom and top plate penetrations through out
---	------	---

Comments: