

FIRE DEPARTMENT

Prevention Division (816)969-1300

PLANS REVIEW CONDITIONS

Permit No: PRCOM20214416 Date: April 25, 2022

Project Title: COOPER'S HAWK WINERY & Applicant:

RESTAURANT

Location: ALLIANCE FIRE PROTECTION LLC

540 NW CHIPMAN RD, LEES SUMMIT, MO 64086 130 W 9TH AVE STE 101
Type of Work: KANSAS CITY, MO 64116

Type of Work:

Occupancy Group: A-2
Description: A-2
NEW FULL SERVICE WINE THEMED Primary: (913) 888-0647

RESTAURANT

Construction Type: Type VB (Unprotected)

Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Jim Eden Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- Call (816) 969-1300 to schedule hydrostatic and flow tests.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.