

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210427
Address: 250 NW MCNARY CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Monday, April 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	:CODES: RESTROOM MIRRORS SHALL BE 40" TO REFLECTIVE SURFACE COMPLETE AWNING ABOVE TRIPLE WINDOW FRONT OF BLDG UPLOAD SPECIAL INSPECTION FINAL REPORT TO PERMIT FIRE TCO OK WATER TCO OK PLANNING FIELD ENGINEERING
---	--------------------------	---

Comments: