

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215864  
Address: 2613 SW HOOK FARM LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, April 26, 2022

Corrective Action Required:

1 Misc

- seal penetrations in joist space used for RA above mud hall
- address rafter/ceiling joists to top plate connection rafters not tied to ceiling joists of top plate
- seal penetration in RA panning above coat closet/washer dryer

**Comments:**