

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215870
Address: 2027 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, April 14, 2022

Corrective Action Required:

1	Misc	-Address garage W garage wall not tied together with front exterior wall -nail off hold down above fireplace -fire block S basement wall 2 spots into furr down -support dwv every 48" above wet bar island in basement
---	------	--

Comments: