

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220280  
Address: 1752 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Failed	Tuesday, April 26, 2022

Corrective Action Required:

1	Misc	PARTIAL PASS SCREW PATTERN APPROVED FOR TAPE DIMISING WALL REPAIR DRYWALL AT DOOR OPENING PASSING THROUGH NEAR RESTROOMS FIRE TAPE SEAMS NEAR FRONT ENTRY PROVIDE CORRECT ADDRESS COMPLETE SPRINKLER & ALARM TEST
---	------	--

**Comments:**