



## COMMENT RESPONSE

---

April 26, 2022

Dawn Bell  
Development Services  
City of Lee's Summit  
220 SE Green St.  
Lee's Summit, Missouri 64063

Re: Permit number: PRCOM20221405  
Lee's Summit Senior Living Community  
SHADE STRUCTURE - PLAN REVIEW

---

The following is in response to plan review comments that have been sent in a letter dated April 25, 2022. Drawing revisions are marked as Delta 30 and listed as PR056 - City Comments.

### **BUILDING PLAN REVIEW**

1. *COMMENT: 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.*

*Action required- A fire extinguisher shall be within 30 feet of the cooking appliance.)*

**RESPONSE:** There is a type K fire extinguisher located inside the door within 30 feet of the cooking area. This has location has been noted on Revised sheet SP1.5.

2. *COMMENT: What is the fuel for the grill? Show piping and shut off if using natural gas. If using propane, how will additional cylinders be stored?*

**RESPONSE:** The fuel source for the gas grill is propane. The owner provides a storage cabinet for additional cylinders. The operator of the facility will be informed that this needs to be located outside within the generator enclosure area.