

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212885
Address: 2114 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, April 26, 2022

Corrective Action Required:

1	Misc	-Obtain lawn irrigation permit and backflow certification -Provide GFCI protection at patio receptacle and basement sump pump receptacle -final grade and sod -splash blocks all downspout and sump pump locations, min 36" discharge from foundation -complete guardrail back patio
---	------	--

Comments: