



ELEVATE  
DESIGN +  
BUILD

April 26, 2022,

Andrea Sessler  
Development Technician  
Plan Services- Code Administration  
220 SE Green Street  
Lee's Summit, MO 64063

Re: Hook Farms Lot 08  
Building Location: 2609 SW Hook Farm Ln  
Project Name: Greystone  
Control Number: PRRES20221673

To whom this concern,

Please find the following responses to plan review comments received for the above listed project.

**Plot Plan Review**

1. Existing and finish elevations at all property corners must be provided on the plot plan.
2. *Contours, spot elevations and drainage flow arrows (as required) shall be provided on the lot.*

*Please add more arrows.*

**This has been provided on the plot plan.**

**Residential Plan Review**

1. *Identify emergency escape openings from bedrooms and basements.*

**This has been provided on sheet A0 for bedroom #4 and sheet A1 for Master Bedroom.**

2. *Designate locations of smoke detectors and carbon monoxide detectors.*

**This has been provided on sheet A2.**

I hope that these responses will satisfy the questions and concerns. If more information is required, please do not hesitate to contact me.

Sincerely,

Leyton Bruegman  
Architect/Designer 1