

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214970
Address: 940 NW PRYOR RD, Unit:M, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1	Miscellaneous Correction	Insulate under sink plumbing in restrooms Provide safety chain deep fryers, range, cooktop, grill Upload health dept inspection to permit
---	--------------------------	---

OK TO STOCK & TRAIN

Comments: