

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214636
Address: 2954 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1	Misc	-tie front entry wall to garage and bed 2 wall there top plates not tied together -stud pack at Gt bearing point front entry wall -fire block dead space between bath 2 and kitchen seals gaps -cspf nailing at dining room windows -fire block into furr down bed 4 closet seal gaps -missing truss hangers above bed 2 closet -nail exterior sheathing to plans/code
---	------	--

Comments: