

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216210  
Address: 4804 NE FREEHOLD CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Shawn Hoffman	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1	Miscellaneous Correction	-No bonding to UFER -Neutral bar not connected ( setup as sub panel) -Jumper required from grounding bar to neutral bar
---	--------------------------	---

**Comments:**