

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216210
Address: 4804 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1 Miscellaneous
Correction

- Provide windows and doors
- Remove wrap on PFH portal frame nail pattern inspection
- Finish R/A panning above bedroom 2 in soffit space , basement
- Fire block top plate exterior wall shower at back of house
- Security blocking basement door
- Provide basement Egress window
- Provide solid blocking at cantilever basement

Comments: