

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214637
Address: 3233 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1	Misc	-attic access in garage protect NM -nail exterior great room windows to plans -complete cspf per plans at all areas -strap top plate in office where plate breaks offset less than 24" -address over bored joist for hvac furnace venting
---	------	---

Comments: