

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214077  
Address: 3104 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                     |
|---|------------------|----------|---------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Wednesday, April 27, 2022 |

Corrective Action Required:

|   |                          |  |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | - Address broken trusses A2 and B1A in kitchen-upload letter to portal for inspection<br>- fire block west wall into furr down in basement |
|---|--------------------------|--|

**Comments:**