



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20216541, Public Works Right of Way Permit
Address: 1909 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Passed	Wednesday, April 27, 2022

Corrective Action Required

1 Misc

Site Visit - The service line has been installed. The yard across the street is a new home build and has not been established prior to Spire's work. The depth mark in the middle of the street is at 2.8 feet. I have taken a picture and uploaded it to the documents tab. I do not see any damage from the depth but I am documenting the depths since it is less than our 3 foot requirement. I have spoken to Craig Picard with Spire prior to this about another site where the curbs were damaged due to a shallow bore under the road that was less than our minimum required 3ft.

Comments: